

## 2U40S2SC1FA

RAFFRESCAMENTO																	
Combinazioni			Potenza resa (kW)		Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			EER	Classe energ.	SEER	Classe energ.
UI	A	B	A	B	min	nom	max	min	nom	max	min	nom	max				
2	2,0	2,0	1,90	1,90	1,10	3,80	4,60	0,29	0,94	1,47	1,2	4,3	6,7	4,04	A	6,20	A++
	2,0	2,5	1,70	2,10	1,10	3,80	4,60	0,30	0,94	1,50	1,3	4,3	6,8	4,04	A	6,20	A++
	2,0	3,5	1,45	2,45	1,10	3,90	4,70	0,30	0,97	1,54	1,3	4,5	7,0	4,02	A	6,20	A++
	2,5	2,5	1,95	1,95	1,10	3,90	4,70	0,30	0,97	1,54	1,3	4,5	7,0	4,02	A	6,20	A++
	2,5	3,5	1,80	2,20	1,10	4,00	4,80	0,30	1,00	1,60	1,3	4,5	7,2	4,00	A	6,20	A++

RISCALDAMENTO																	
Combinazioni			Potenza resa (kW)		Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			COP	Classe energ.	SCOP	Classe energ.
UI	A	B	A	B	min	nom	max	min	nom	max	min	nom	max				
2	2,0	2,0	2,10	2,10	1,80	4,20	4,80	0,38	1,07	1,84	1,7	4,9	8,4	3,93	A	4,00	A+
	2,0	2,5	1,80	2,40	1,80	4,20	4,90	0,38	1,06	1,88	1,7	4,9	8,6	3,96	A	4,00	A+
	2,0	3,5	1,60	2,80	1,80	4,40	5,00	0,38	1,11	1,88	1,7	5,0	8,6	3,97	A	4,00	A+
	2,5	2,5	2,20	2,20	1,80	4,40	5,00	0,38	1,09	1,88	1,7	5,0	8,6	4,03	A	4,00	A+
	2,5	3,5	2,00	2,40	1,80	4,40	5,20	0,38	1,07	1,95	1,7	4,8	8,7	4,10	A	4,00	A+

(i valori in tabella si riferiscono alla linea DAWN)

## 2U50S2SF1FA

RAFFRESCAMENTO																	
Combinazioni			Potenza resa (kW)		Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			EER	Classe energ.	SEER	Classe energ.
UI	A	B	A	B	min	nom	max	min	nom	max	min	nom	max				
2	2,0	2,0	2,45	2,45	1,30	4,90	5,60	0,33	1,36	2,27	1,6	6,1	10,2	3,60	A	6,50	A++
	2,0	2,5	2,20	2,70	1,30	4,90	5,60	0,33	1,36	2,27	1,6	6,1	10,2	3,60	A	6,50	A++
	2,0	3,5	2,00	3,00	1,30	5,00	5,80	0,35	1,41	2,33	1,7	6,3	10,6	3,55	A	6,50	A++
	2,0	4,2	1,80	3,20	1,30	5,00	5,80	0,35	1,45	2,33	1,7	6,5	10,6	3,45	A	6,50	A++
	2,5	2,5	2,50	2,50	1,30	5,00	5,80	0,35	1,41	2,33	1,6	6,3	10,4	3,55	A	6,50	A++
	2,5	3,5	2,00	2,75	1,30	5,10	5,90	0,35	1,38	2,35	1,6	6,2	10,5	3,69	A	6,50	A++
	2,5	4,2	2,30	2,80	1,30	5,10	5,90	0,38	1,45	2,35	1,6	6,5	10,5	3,52	A	6,50	A++
	3,5	3,5	2,55	2,55	1,30	5,10	6,00	0,38	1,41	2,40	1,6	6,3	10,7	3,62	A	6,50	A++
	3,5	4,2	2,50	2,70	1,30	5,20	6,00	0,38	1,43	2,40	1,7	6,4	10,7	3,63	A	6,50	A++
	4,2	4,2	2,60	2,60	1,30	5,20	6,10	0,38	1,43	2,50	1,7	6,4	11,2	3,63	A	6,50	A++

RISCALDAMENTO																	
Combinazioni			Potenza resa (kW)		Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			COP	Classe energ.	SCOP	Classe energ.
UI	A	B	A	B	min	nom	max	min	nom	max	min	nom	max				
2	2,0	2,0	2,75	2,75	1,50	5,50	6,30	0,49	1,51	2,37	2,2	6,8	10,9	3,64	A	4,00	A+
	2,0	2,5	2,45	3,05	1,50	5,50	6,30	0,49	1,51	2,37	2,2	6,8	10,9	3,64	A	4,00	A+
	2,0	3,5	2,15	3,45	1,60	5,60	6,40	0,52	1,53	2,37	2,3	6,9	10,9	3,66	A	4,00	A+
	2,0	4,2	1,85	3,75	1,60	5,60	6,40	0,52	1,54	2,37	2,6	6,9	10,7	3,63	A	4,00	A+
	2,5	2,5	2,80	2,80	1,60	5,60	6,40	0,52	1,53	2,37	2,3	6,8	10,9	3,66	A	4,00	A+
	2,5	3,5	2,60	3,10	1,70	5,70	6,50	0,53	1,55	2,40	2,4	7,0	10,6	3,67	A	4,00	A+
	2,5	4,2	2,40	3,30	1,70	5,70	6,50	0,53	1,57	2,40	2,4	7,1	10,7	3,63	A	4,00	A+
	3,5	3,5	2,85	2,85	1,80	5,70	6,60	0,55	1,53	2,45	2,5	6,9	10,9	3,72	A	4,00	A+
	3,5	4,2	2,90	3,00	1,90	5,90	6,60	0,55	1,56	2,45	2,6	7,3	11,4	3,78	A	4,00	A+
	4,2	4,2	2,95	2,95	1,90	5,90	6,70	0,55	1,56	2,55	2,6	7,3	11,4	3,78	A	4,00	A+

(i valori in tabella si riferiscono alla linea DAWN)

3U5S2SR2FA

RAFFRESCAMENTO																			
Combinazioni			Potenza resa (kW)			Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			EER	Classe energ.	SEER	Classe energ.	
UI	A	B	C	A	B	C	min	nom	max	min	nom	max	min	nom	max				
1	2.0	—	—	2.00	—	—	0.80	2.00	2.80	0.55	0.62	1.50	2.44	2.75	6.65	3.23	A	6.50	A++
	2.5	—	—	2.60	—	—	0.80	2.60	3.90	0.55	0.78	1.65	2.44	3.46	7.32	3.33	A	6.50	A++
	3.5	—	—	3.60	—	—	1.00	3.60	5.30	0.55	1.07	1.76	2.44	4.75	7.81	3.36	A	6.50	A++
	4.2	—	—	4.40	—	—	1.30	4.40	5.00	0.55	1.28	2.15	2.44	5.68	9.54	3.44	A	6.50	A++
	5.0	—	—	5.2	—	—	1.40	5.2	7.00	0.55	1.48	2.24	2.44	6.57	9.94	3.51	A	6.50	A++
2	2.0	2.0	—	2.00	2.00	—	1.60	4.00	5.60	0.55	1.18	2.50	2.44	5.24	11.09	3.39	A	6.60	A++
	2.0	2.5	—	2.00	2.60	—	1.80	4.60	6.70	0.55	1.32	2.50	2.44	5.86	11.09	3.48	A	6.70	A++
	2.0	3.5	—	1.96	3.54	—	2.10	5.50	7.00	0.55	1.55	2.50	2.44	6.88	11.09	3.55	A	6.80	A++
	2.0	4.2	—	1.72	3.78	—	2.10	5.50	7.00	0.55	1.54	2.50	2.44	6.83	11.09	3.57	A	6.80	A++
	2.0	5.0	—	1.53	3.97	—	2.10	5.50	7.00	0.55	1.54	2.50	2.44	6.83	11.09	3.57	A	6.80	A++
	2.5	2.5	—	2.60	2.60	—	2.00	5.20	7.00	0.55	1.49	2.50	2.44	6.61	11.09	3.49	A	6.80	A++
	2.5	3.5	—	2.18	3.02	—	2.10	5.20	7.00	0.55	1.53	2.50	2.44	6.79	11.09	3.40	A	6.30	A++
	2.5	4.2	—	2.04	3.46	—	2.10	5.50	7.00	0.55	1.52	2.50	2.44	6.74	11.09	3.62	A	6.80	A++
	2.5	5.0	—	1.83	3.67	—	2.10	5.50	7.00	0.55	1.50	2.50	2.44	6.65	11.09	3.67	A	6.80	A++
	3.5	3.5	—	2.75	2.75	—	2.10	5.50	7.00	0.55	1.50	2.50	2.44	6.65	11.09	3.67	A	6.80	A++
3	2.0	2.0	2.0	1.83	1.83	1.83	2.10	5.50	7.00	0.55	1.45	2.50	2.44	6.43	11.09	3.79	A	7.20	A++
	2.0	2.0	2.5	1.67	1.67	2.17	2.10	5.50	7.00	0.55	1.45	2.50	2.44	6.43	11.09	3.79	A	7.20	A++
	2.0	2.0	3.5	1.45	1.45	2.61	2.10	5.50	7.00	0.55	1.43	2.50	2.44	6.34	11.09	3.85	A	7.30	A++
	2.0	2.5	2.5	1.53	1.99	1.99	2.10	5.50	7.00	0.55	1.43	2.50	2.44	6.34	11.09	3.85	A	7.40	A++
	2.0	2.5	3.5	1.34	1.74	2.41	2.10	5.50	7.00	0.55	1.42	2.50	2.44	6.30	11.09	3.87	A	7.40	A++
	2.5	2.5	2.5	1.83	1.83	1.83	2.10	5.50	7.00	0.55	1.37	2.50	2.44	6.08	11.09	4.01	A	7.50	A++
2.5	2.5	3.5	1.63	1.63	2.25	2.10	5.50	7.00	0.55	1.37	2.50	2.44	6.08	11.09	4.01	A	7.50	A++	

RISCALDAMENTO																			
Combinazioni			Potenza resa (kW)			Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			COP	Classe energ.	SCOP	Classe energ.	
UI	A	B	C	A	B	C	min	nom	max	min	nom	max	min	nom	max				
1	2.0	—	—	2.30	—	—	0.80	2.30	4.00	0.55	0.63	1.80	2.44	2.80	7.99	3.65	A	3.50	A
	2.5	—	—	3.60	—	—	0.80	3.60	6.00	0.55	0.98	1.90	2.44	4.35	8.43	3.67	A	3.50	A
	3.5	—	—	4.50	—	—	1.00	4.50	6.00	0.55	1.20	2.00	2.44	5.32	8.87	3.75	A	3.50	A
	4.2	—	—	5.40	—	—	1.50	5.40	6.00	0.55	1.40	2.00	2.44	6.21	8.87	3.86	A	3.60	A
	5.0	—	—	6.00	—	—	1.50	6.00	7.60	0.55	1.55	2.20	2.44	6.88	9.76	3.87	A	3.60	A
2	2.0	2.0	—	2.30	2.30	—	1.20	4.60	7.60	0.55	1.25	2.10	2.44	5.55	9.32	3.68	A	3.70	A
	2.0	2.5	—	2.30	3.60	—	1.20	5.90	7.60	0.55	1.54	2.10	2.44	6.83	9.32	3.83	A	3.75	A
	2.0	3.5	—	2.30	4.50	—	1.20	6.80	7.60	0.55	1.72	2.10	2.44	7.63	9.32	3.95	A	3.75	A
	2.0	4.2	—	2.03	4.77	—	1.70	6.80	7.60	0.55	1.70	2.10	2.44	7.54	9.32	4.00	A	3.75	A
	2.0	5.0	—	1.88	4.92	—	1.70	6.80	7.60	0.55	1.70	2.10	2.44	7.54	9.32	4.00	A	3.75	A
	2.5	2.5	—	3.40	3.40	—	1.70	6.80	7.60	0.55	1.68	2.20	2.44	7.45	9.76	4.05	A	3.80	A
	2.5	3.5	—	2.89	3.61	—	1.70	6.50	7.60	0.55	1.68	2.20	2.44	7.45	9.76	3.87	A	3.80	A
	2.5	4.2	—	2.72	4.08	—	1.70	6.80	7.60	0.55	1.66	2.20	2.44	7.36	9.76	4.10	A	3.80	A
	2.5	5.0	—	2.55	4.25	—	1.70	6.80	7.60	0.55	1.66	2.20	2.44	7.36	9.76	4.10	A	3.85	A
	3.5	3.5	—	3.40	3.40	—	1.70	6.80	7.60	0.55	1.66	2.20	2.44	7.36	9.76	4.10	A	3.85	A
3	2.0	2.0	2.0	2.27	2.27	2.27	1.70	6.80	7.60	0.55	1.64	2.20	2.44	7.28	9.76	4.15	A	3.90	A
	2.0	2.0	2.5	1.91	1.91	2.99	1.70	6.80	7.60	0.55	1.63	2.20	2.44	7.23	9.76	4.17	A	3.90	A
	2.0	2.0	3.5	1.72	1.72	3.36	1.70	6.80	7.60	0.55	1.63	2.20	2.44	7.23	9.76	4.17	A	3.90	A
	2.0	2.5	2.5	1.65	2.58	2.58	1.70	6.80	7.60	0.55	1.62	2.20	2.44	7.19	9.76	4.20	A	3.95	A
	2.0	2.5	3.5	1.50	2.35	2.94	1.70	6.80	7.60	0.55	1.62	2.20	2.44	7.19	9.76	4.20	A	3.95	A
	2.5	2.5	2.5	2.27	2.27	2.27	1.70	6.80	7.60	0.55	1.55	2.20	2.44	6.88	9.76	4.39	A	4.00	A+
2.5	2.5	3.5	2.09	2.09	2.62	1.70	6.80	7.60	0.55	1.55	2.20	2.44	6.88	9.76	4.39	A	4.00	A+	

## 3U70S2SR2FA

RAFFRESCAMENTO																			
Combinazioni				Potenza resa (kW)			Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			EER	Classe energ.	SEER	Classe energ.
UI	A	B	C	A	B	C	min	nom	max	min	nom	max	min	nom	max				
1	2.0	—	—	2.00	—	—	0.80	2.00	2.80	0.55	0.62	1.30	2.44	2.75	5.8	3.23	A	6.40	A++
	2.5	—	—	2.60	—	—	0.80	2.60	3.90	0.55	0.79	1.34	2.44	3.50	5.9	3.29	A	6.40	A++
	3.5	—	—	3.60	—	—	1.00	3.60	5.30	0.55	1.09	1.65	2.44	4.84	7.3	3.30	A	6.40	A++
	4.2	—	—	4.40	—	—	1.30	4.40	5.00	0.55	1.32	1.90	2.44	5.86	8.43	3.33	A	6.40	A++
	5.0	—	—	5.20	—	—	1.40	5.20	7.00	0.55	1.55	2.00	2.44	6.88	8.9	3.35	A	6.40	A++
	7.1	—	—	6.50	—	—	1.50	6.50	7.40	0.55	1.92	2.60	2.44	8.52	11.5	3.39	A	6.40	A++
2	2.0	2.0	—	2.00	2.00	—	1.80	4.00	5.60	0.55	1.21	2.60	2.44	5.37	11.5	3.31	A	6.60	A++
	2.0	2.5	—	2.00	2.60	—	1.80	4.60	6.70	0.55	1.35	2.64	2.44	5.99	11.7	3.41	A	6.60	A++
	2.0	3.5	—	2.00	3.60	—	1.80	5.60	7.50	0.55	1.65	2.95	2.44	7.32	13.1	3.39	A	6.60	A++
	2.0	4.2	—	2.00	4.40	—	1.80	6.40	7.60	0.55	1.89	3.00	2.44	8.39	13.3	3.39	A	6.70	A++
	2.0	5.0	—	1.94	5.06	—	2.40	7.00	7.60	0.55	2.02	3.00	2.44	8.96	13.3	3.47	A	6.70	A++
	2.5	2.5	—	2.60	2.60	—	2.00	5.20	7.40	0.55	1.52	2.68	2.44	6.74	11.9	3.42	A	6.70	A++
	2.5	3.5	—	2.60	3.60	—	2.00	6.20	7.60	0.55	1.79	2.99	2.44	7.94	13.3	3.46	A	6.70	A++
	2.5	4.2	—	2.60	4.40	—	2.40	7.00	7.60	0.55	2.02	3.00	2.44	8.96	13.3	3.47	A	6.70	A++
	2.5	5.0	—	2.33	4.67	—	2.40	7.00	7.60	0.55	2.00	3.00	2.44	8.87	13.3	3.50	A	6.70	A++
	3.5	3.5	—	3.40	3.40	—	2.40	6.80	7.60	0.55	2.00	3.20	2.44	8.87	14.2	3.40	A	6.20	A++
	3.5	4.2	—	3.15	3.85	—	2.40	7.00	7.60	0.55	1.82	3.20	2.44	8.07	14.2	3.85	A	6.80	A++
3.5	5.0	—	2.86	4.14	—	2.40	7.00	7.60	0.55	1.82	3.20	2.44	8.07	14.2	3.85	A	6.80	A++	
4.2	4.2	—	3.50	3.50	—	2.40	7.00	7.60	0.55	1.82	3.20	2.44	8.07	14.2	3.85	A	6.80	A++	
3	2.0	2.0	2.0	2.00	2.00	2.00	2.40	6.00	7.60	0.55	1.75	2.70	2.44	7.76	12.0	3.43	A	7.20	A++
	2.0	2.0	2.5	2.00	2.00	2.60	2.40	6.60	7.60	0.55	1.75	2.70	2.44	7.76	12.0	3.77	A	7.20	A++
	2.0	2.0	3.5	1.84	1.84	3.32	2.40	7.00	7.60	0.55	1.80	2.70	2.44	7.99	12.0	3.89	A	7.20	A++
	2.0	2.0	4.2	1.67	1.67	3.67	2.40	7.00	7.60	0.55	1.80	2.70	2.44	7.99	12.0	3.89	A	7.20	A++
	2.0	2.0	5.0	1.52	1.52	3.96	2.40	7.00	7.60	0.55	1.80	2.70	2.44	7.99	12.0	3.89	A	7.20	A++
	2.0	2.5	2.5	1.94	2.53	2.53	2.40	7.00	7.60	0.55	1.80	2.70	2.44	7.99	12.0	3.89	A	7.30	A++
	2.0	2.5	3.5	1.71	2.22	3.07	2.40	7.00	7.60	0.55	1.80	2.70	2.44	7.99	12.0	3.89	A	7.30	A++
	2.0	2.5	4.2	1.56	2.02	3.42	2.40	7.00	7.60	0.55	1.80	2.70	2.44	7.99	12.0	3.89	A	7.30	A++
	2.0	2.5	5.0	1.43	1.86	3.71	2.40	7.00	7.60	0.55	1.82	2.70	2.44	8.07	12.0	3.85	A	7.30	A++
	2.0	3.5	3.5	1.52	2.74	2.74	2.40	7.00	7.60	0.55	1.82	2.70	2.44	8.07	12.0	3.85	A	7.40	A++
	2.0	3.5	4.2	1.40	2.52	3.08	2.40	7.00	7.60	0.55	1.80	2.70	2.44	7.99	12.0	3.89	A	7.40	A++
	2.5	2.5	2.5	2.33	2.33	2.33	2.40	7.00	7.60	0.55	1.76	2.70	2.44	7.81	12.0	3.98	A	7.50	A++
	2.5	2.5	3.5	2.07	2.07	2.86	2.40	7.00	7.60	0.55	1.78	2.70	2.44	7.90	12.0	3.93	A	7.50	A++
	2.5	2.5	4.2	1.90	1.90	3.21	2.40	7.00	7.60	0.55	1.78	2.70	2.44	7.90	12.0	3.93	A	7.50	A++
	2.5	3.5	3.5	1.86	2.57	2.57	2.40	7.00	7.60	0.55	1.78	2.70	2.44	7.90	12.0	3.93	A	7.50	A++

RISCALDAMENTO																			
Combinazioni				Potenza resa (kW)			Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			COP	Classe energ.	SCOP	Classe energ.
UI	A	B	C	A	B	C	min	nom	max	min	nom	max	min	nom	max				
1	2.0	—	—	2.30	—	—	0.80	2.30	4.00	0.55	0.64	1.40	2.44	2.83	6.21	3.61	A	3.70	A
	2.5	—	—	3.60	—	—	0.80	3.60	6.00	0.55	0.98	1.50	2.44	4.35	6.65	3.67	A	3.70	A
	3.5	—	—	4.50	—	—	1.00	4.50	6.00	0.55	1.22	1.65	2.44	5.41	7.32	3.69	A	3.70	A
	4.2	—	—	5.40	—	—	1.50	5.40	6.00	0.55	1.45	1.90	2.44	6.43	8.43	3.72	A	3.70	A
	5.0	—	—	6.00	—	—	1.50	6.00	8.00	0.55	1.60	2.00	2.44	7.10	8.87	3.75	A	3.70	A
	7.1	—	—	7.00	—	—	1.50	7.00	8.60	0.55	1.84	2.20	2.44	8.16	9.76	3.80	A	3.70	A
2	2.0	2.0	—	2.30	2.30	—	2.60	4.60	8.00	0.55	1.25	2.00	2.44	5.55	8.87	3.68	A	3.80	A
	2.0	2.5	—	2.30	3.60	—	2.70	5.90	8.50	0.55	1.60	2.00	2.44	7.10	8.87	3.69	A	3.80	A
	2.0	3.5	—	2.30	4.50	—	2.70	6.80	8.50	0.55	1.82	2.10	2.44	8.07	9.32	3.74	A	3.80	A
	2.0	4.2	—	2.27	5.33	—	2.90	7.60	8.50	0.55	2.06	2.10	2.44	9.14	9.32	3.69	A	3.90	A
	2.0	5.0	—	2.11	5.49	—	2.90	7.60	8.50	0.55	2.05	2.10	2.44	9.09	9.32	3.71	A	3.90	A
	2.5	2.5	—	3.60	3.60	—	2.90	7.20	8.50	0.55	1.93	2.10	2.44	8.56	9.32	3.73	A	3.90	A
	2.5	3.5	—	3.38	4.22	—	2.90	7.60	8.50	0.55	2.05	2.10	2.44	9.09	9.32	3.71	A	3.90	A
	2.5	4.2	—	3.04	4.56	—	2.90	7.60	8.50	0.55	2.06	2.10	2.44	9.14	9.32	3.69	A	3.95	A
	2.5	5.0	—	2.85	4.75	—	2.90	7.60	8.50	0.55	2.05	2.10	2.44	9.09	9.32	3.71	A	3.95	A
	3.5	3.5	—	3.75	3.75	—	2.90	7.50	8.50	0.55	1.93	2.20	2.44	8.54	9.76	3.90	A	3.80	A
	3.5	4.2	—	3.45	4.15	—	2.90	7.60	8.50	0.55	2.02	2.20	2.44	8.96	9.76	3.76	A	4.00	A+
3.5	5.0	—	3.26	4.34	—	2.90	7.60	8.50	0.55	2.00	2.20	2.44	8.87	9.76	3.80	A	4.00	A+	
4.2	4.2	—	3.80	3.80	—	2.90	7.60	8.50	0.55	2.00	2.20	2.44	8.87	9.76	3.80	A	4.00	A+	
3	2.0	2.0	2.0	2.30	2.30	2.30	2.90	6.90	8.50	0.55	1.85	2.30	2.44	8.21	10.20	3.73	A	4.05	A+
	2.0	2.0	2.5	2.13	2.13	3.34	2.90	7.60	8.50	0.55	1.98	2.30	2.44	8.78	10.20	3.84	A	4.05	A+
	2.0	2.0	3.5	1.92	1.92	3.76	2.90	7.60	8.50	0.55	1.96	2.30	2.44	8.70	10.20	3.88	A	4.05	A+
	2.0	2.0	4.2	1.75	1.75	4.10	2.90	7.60	8.50	0.55	1.95	2.30	2.44	8.65	10.20	3.90	A	4.05	A+
	2.0	2.0	5.0	1.65	1.65	4.30	2.90	7.60	8.50	0.55	1.95	2.30	2.44	8.65	10.20	3.90	A	4.05	A+
	2.0	2.5	2.5	1.84	2.88	2.88	2.90	7.60	8.50	0.55	1.90	2.30	2.44	8.43	10.20	4.00	A	4.08	A+
	2.0	2.5	3.5	1.68	2.63	3.29	2.90	7.60	8.50	0.55	1.85	2.30	2.44	8.21	10.20	4.11	A	4.08	A+
	2.0	2.5	4.2	1.55	2.42	3.63	2.90	7.60	8.50	0.55	1.85	2.30	2.44	8.21	10.20	4.11	A	4.08	A+
	2.0	2.5	5.0	1.47	2.30	3.83	2.90	7.60	8.50	0.55	1.86	2.30	2.44	8.25	10.20	4.09	A	4.08	A+
	2.0	3.5	3.5	1.55	3.03	3.03	2.90	7.60	8.50	0.55	1.88	2.30	2.44	8.34	10.20	4.04	A	4.10	A+
	2.0	3.5	4.2	1.43	2.80	3.36	2.90	7.60	8.50	0.55	1.85	2.30	2.44	8.21	10.20	4.11	A	4.10	A+
	2.5	2.5	2.5	2.53	2.53	2.53	2.90	7.60	8.50	0.55	1.81	2.30	2.44	8.03	10.20	4.20	A	4.20	A+
	2.5	2.5	3.5	2.34	2.34	2.92	2.90	7.60	8.50	0.55	1.84	2.30	2.44	8.16	10.20	4.13	A	4.20	A+
	2.5	2.5	4.2	2.17	2.17	3.26	2.90	7.60	8.50	0.55	1.84	2.30	2.44	8.16	10.20	4.13	A	4.20	A+
	2.5	3.5	3.5	2.17	2.71	2.71	2.90	7.60	8.50	0.55	1.84	2.30	2.44	8.16	10.20	4.13	A	4.20	A+

## 4U75S2SR2FA

RAFFRESCAMENTO																						
Combinazioni				Potenza resa (kW)				Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			EER	Classe energ.	SEER	Classe energ.		
UI	A	B	C	A	B	C	min	nom	max	min	nom	max	min	nom	max	min	nom					
1	2.0	—	—	—	2.00	—	—	—	0.80	2.00	2.80	0.55	0.66	1.30	2.44	2.93	5.77	3.03	B	6.20	A++	
	2.5	—	—	—	2.60	—	—	—	0.80	2.60	3.90	0.55	0.86	1.34	2.44	3.82	5.93	3.02	B	6.20	A++	
	3.5	—	—	—	3.60	—	—	—	1.00	3.60	5.30	0.55	1.20	1.50	2.44	5.32	6.65	3.00	B	6.20	A++	
	4.2	—	—	—	4.40	—	—	—	1.30	4.40	5.00	0.55	1.40	1.90	2.44	6.21	8.43	3.14	B	6.20	A++	
	5.0	—	—	—	5.20	—	—	—	1.40	5.20	7.00	0.55	1.65	1.90	2.44	7.32	8.43	3.15	B	6.20	A++	
	7.1	—	—	—	6.50	—	—	—	1.50	6.50	7.40	0.55	2.05	2.80	2.44	9.09	12.42	3.17	B	6.20	A++	
	2.0	2.0	—	—	2.00	2.00	—	—	2.00	4.00	5.60	0.55	1.30	3.00	2.44	5.77	13.31	3.08	B	6.20	A++	
	2.0	2.5	—	—	2.00	2.60	—	—	2.00	4.60	6.70	0.55	1.50	3.00	2.44	6.65	13.31	3.07	B	6.20	A++	
	2.0	3.5	—	—	2.00	3.60	—	—	2.00	5.60	8.10	0.55	1.80	3.00	2.44	7.99	13.31	3.11	B	6.20	A++	
	2.0	4.2	—	—	2.00	4.40	—	—	2.00	6.40	7.80	0.55	1.95	3.00	2.44	8.65	13.31	3.28	A	6.20	A++	
	2.0	5.0	—	—	2.00	5.20	—	—	2.00	7.20	8.70	0.55	2.20	3.00	2.44	9.76	13.31	3.27	A	6.20	A++	
	2.0	7.1	—	—	1.76	5.74	—	—	2.00	7.50	8.70	0.55	2.24	3.10	2.44	9.94	13.75	3.35	A	6.20	A++	
	2.5	2.5	—	—	2.60	2.60	—	—	2.00	5.20	7.80	0.55	1.70	3.10	2.44	7.54	13.75	3.06	B	6.20	A++	
	2.5	3.5	—	—	2.60	3.60	—	—	2.00	6.20	8.70	0.55	2.00	3.10	2.44	8.87	13.75	3.10	B	6.20	A++	
	2.5	4.2	—	—	2.60	4.40	—	—	2.00	7.00	8.70	0.55	2.10	3.10	2.44	9.32	13.75	3.33	A	6.20	A++	
	2.5	5.0	—	—	2.50	5.00	—	—	2.00	7.50	8.70	0.55	2.24	3.10	2.44	9.94	13.75	3.35	A	6.20	A++	
	2.5	7.1	—	—	2.14	5.36	—	—	2.00	7.50	8.70	0.55	2.24	3.10	2.44	9.94	13.75	3.35	A	6.20	A++	
	3.5	3.5	—	—	3.60	3.60	—	—	2.00	7.20	8.70	0.55	2.20	3.10	2.44	9.76	13.75	3.27	A	6.20	A++	
	3.5	4.2	—	—	3.38	4.12	—	—	2.00	7.50	8.70	0.55	2.26	3.20	2.44	10.03	14.20	3.32	A	6.20	A++	
	3.5	5.0	—	—	2.95	4.25	—	—	2.00	7.20	8.70	0.55	2.24	3.20	2.44	9.94	14.20	3.21	A	6.20	A++	
	3.5	7.1	—	—	2.67	4.83	—	—	2.00	7.50	8.70	0.55	2.25	3.20	2.44	9.98	14.20	3.33	A	6.20	A++	
	4.2	4.2	—	—	3.75	3.75	—	—	2.00	7.50	8.70	0.55	2.25	3.20	2.44	9.98	14.20	3.33	A	6.20	A++	
	4.2	5.0	—	—	3.44	4.06	—	—	2.00	7.50	8.70	0.55	2.25	3.20	2.44	9.98	14.20	3.33	A	6.20	A++	
	4.2	7.1	—	—	3.03	4.47	—	—	2.00	7.50	8.70	0.55	2.25	3.30	2.44	9.98	14.64	3.33	A	6.20	A++	
	5.0	5.0	—	—	3.75	3.75	—	—	2.00	7.50	8.70	0.55	2.18	3.30	2.44	9.67	14.64	3.44	A	6.20	A++	
	5.0	7.1	—	—	3.33	4.17	—	—	2.00	7.50	8.70	0.55	2.18	3.30	2.44	9.67	14.64	3.44	A	6.20	A++	
	2.0	2.0	2.0	—	2.00	2.00	2.00	—	2.40	6.00	8.70	0.55	1.80	3.40	2.44	7.99	15.08	3.33	A	6.70	A++	
	2.0	2.0	2.5	—	2.00	2.00	2.60	—	2.40	6.60	8.70	0.55	1.95	3.40	2.44	8.65	15.08	3.38	A	6.70	A++	
	2.0	2.0	3.5	—	1.97	1.97	3.55	—	2.40	7.50	8.70	0.55	2.20	3.40	2.44	9.76	15.08	3.41	A	6.70	A++	
	2.0	2.0	4.2	—	1.79	1.79	3.93	—	2.40	7.50	8.70	0.55	2.20	3.40	2.44	9.76	15.08	3.41	A	6.70	A++	
	2.0	2.0	5.0	—	1.63	1.63	4.24	—	2.40	7.50	8.70	0.55	2.20	3.40	2.44	9.76	15.08	3.41	A	6.70	A++	
	2.0	2.0	7.1	—	1.43	1.43	4.64	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.0	2.5	2.5	—	2.00	2.60	2.60	—	2.40	7.20	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.35	A	6.70	A++	
	2.0	2.5	3.5	—	1.83	2.38	3.29	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.0	2.5	4.2	—	1.67	2.17	3.67	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.0	2.5	5.0	—	1.53	1.99	3.98	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.0	2.5	7.1	—	1.35	1.76	4.39	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.0	3.5	3.5	—	1.63	2.93	2.93	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.0	3.5	4.2	—	1.50	2.70	3.30	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.0	3.5	5.0	—	1.39	2.50	3.61	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.0	3.5	7.1	—	1.24	2.23	4.03	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.0	4.2	4.2	—	1.39	3.06	3.06	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.0	4.2	5.0	—	1.29	2.84	3.36	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.0	4.2	7.1	—	1.16	2.56	3.78	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.5	2.5	2.5	—	2.50	2.50	2.50	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.72	A++	
	2.5	2.5	3.5	—	2.22	2.22	3.07	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.72	A++	
	2.5	2.5	4.2	—	2.03	2.03	3.44	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.74	A++	
	2.5	2.5	5.0	—	1.88	1.88	3.75	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.74	A++	
	2.5	2.5	7.1	—	1.67	1.67	4.17	—	2.40	7.50	8.70	0.55	2.15	3.40	2.44	9.54	15.08	3.49	A	6.70	A++	
	2.5	3.5	3.5	—	1.99	2.76	2.76	—	2.40	7.50	8.70	0.55	2.08	3.40	2.44	9.23	15.08	3.61	A	6.73	A++	
	2.5	3.5	4.2	—	1.84	2.55	3.11	—	2.40	7.50	8.70	0.55	2.08	3.40	2.44	9.23	15.08	3.61	A	6.70	A++	
	2.5	3.5	5.0	—	1.71	2.37	3.42	—	2.40	7.50	8.70	0.55	2.08	3.40	2.44	9.23	15.08	3.61	A	6.70	A++	
	2.5	3.5	7.1	—	1.54	2.13	3.84	—	2.40	7.50	8.70	0.55	2.08	3.40	2.44	9.23	15.08	3.61	A	6.70	A++	
	2.5	4.2	4.2	—	1.71	2.89	2.89	—	2.40	7.50	8.70	0.55	2.08	3.40	2.44	9.23	15.08	3.61	A	6.70	A++	
	2.5	4.2	5.0	—	1.60	2.70	3.20	—	2.40	7.50	8.70	0.55	2.08	3.40	2.44	9.23	15.08	3.61	A	6.70	A++	
	3.5	3.5	3.5	—	2.50	2.50	2.50	—	2.40	7.50	8.70	0.55	2.08	3.40	2.44	9.23	15.08	3.61	A	6.75	A++	
	3.5	3.5	4.2	—	2.33	2.33	2.84	—	2.40	7.50	8.70	0.55	2.08	3.40	2.44	9.23	15.08	3.61	A	6.70	A++	
	3.5	3.5	5.0	—	2.18	2.18	3.15	—	2.40	7.50	8.70	0.55	2.08	3.40	2.44	9.23	15.08	3.61	A	6.70	A++	
	2.0	2.0	2.0	2.0	1.88	1.88	1.88	1.88	2.40	7.50	8.70	0.55	2.12	3.40	2.44	9.41	15.08	3.54	A	6.80	A++	
	2.0	2.0	2.0	2.5	1.74	1.74	1.74	2.27	2.40	7.50	8.70	0.55	2.12	3.40	2.44	9.41	15.08	3.54	A	6.80	A++	
	2.0	2.0	2.0	3.5	1.56	1.56	1.56	2.81	2.40	7.50	8.70	0.55	2.12	3.40	2.44	9.41	15.08	3.54	A	6.80	A++	
	2.0	2.0	2.0	4.2	1.44	1.44	1.44	3.17	2.40	7.50	8.70	0.55	2.12	3.40	2.44	9.41	15.08	3.54	A	6.80	A++	
	2.0	2.0	2.0	5.0	1.34	1.34	1.34	3.48	2.40	7.50	8.70	0.55	2.02	3.40	2.44	8.96	15.08	3.71	A	6.80	A++	
	2.0	2.0	2.0	7.1	1.20	1.20	1.20	3.90	2.40	7.50	8.70	0.55	2.02	3.40	2.44	8.96	15.08	3.71	A	6.70	A++	
	2.0	2.0	2.5	2.5	1.63	1.63	2.12	2.12	2.40	7.50	8.70	0.55	2.02	3.40	2.44	8.96	15.08	3.71	A	6.80	A++	
	2.0	2.0	2.5	3.5	1.47	1.47	1.91	2.65	2.40	7.50	8.70	0.55	2.02	3.40	2.44	8.96	15.08	3.71	A	6.		

4U75S2SR2FA

RISCALDAMENTO																						
Combinazioni				Potenza resa (kW)				Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			COP	Classe energ.	SCOP	Classe energ.		
UI	A	B	C	A	B	C	min	nom	max	min	nom	max	min	nom	max	min	nom	COP	Classe energ.	SCOP	Classe energ.	
1	2.0	—	—	—	2.30	—	—	—	0.80	2.30	4.00	0.55	0.63	1.50	2.44	2.80	6.65	3.65	A	3.70	A	
	2.5	—	—	—	3.60	—	—	—	0.80	3.60	6.00	0.55	0.98	1.40	2.44	4.35	6.21	3.67	A	3.70	A	
	3.5	—	—	—	4.50	—	—	—	1.00	4.50	6.00	0.55	1.21	1.50	2.44	5.37	6.65	3.72	A	3.70	A	
	4.2	—	—	—	5.40	—	—	—	1.50	5.40	6.00	0.55	1.44	1.90	2.44	6.39	8.43	3.75	A	3.70	A	
	5.0	—	—	—	6.00	—	—	—	1.50	6.00	8.00	0.55	1.59	2.60	2.44	7.05	11.54	3.77	A	3.70	A	
	7.1	—	—	—	7.00	—	—	—	1.50	7.00	8.60	0.55	1.83	2.60	2.44	8.12	11.54	3.83	A	3.70	A	
	7.1	—	—	—	7.00	—	—	—	1.50	7.00	8.60	0.55	1.83	2.60	2.44	8.12	11.54	3.83	A	3.70	A	
2	2.0	2.0	—	—	2.30	2.30	—	—	2.80	4.60	8.00	0.55	1.25	2.90	2.44	5.55	12.87	3.68	A	3.75	A	
	2.0	2.5	—	—	2.30	3.60	—	—	2.80	5.90	9.00	0.55	1.59	2.90	2.44	7.05	12.87	3.71	A	3.75	A	
	2.0	3.5	—	—	2.30	4.50	—	—	2.80	6.80	10.00	0.55	1.83	2.90	2.44	8.12	12.87	3.72	A	3.75	A	
	2.0	4.2	—	—	2.30	5.40	—	—	3.10	7.70	10.00	0.55	2.05	2.90	2.44	9.09	12.87	3.76	A	3.80	A	
	2.0	5.0	—	—	2.30	6.00	—	—	3.10	8.30	10.00	0.55	2.22	2.90	2.44	9.85	12.87	3.74	A	3.80	A	
	2.0	7.1	—	—	2.13	6.47	—	—	3.10	8.60	10.00	0.55	2.30	2.90	2.44	10.20	12.87	3.74	A	3.85	A	
	2.5	2.5	—	—	3.60	3.60	—	—	3.10	7.20	10.00	0.55	1.94	2.90	2.44	8.61	12.87	3.71	A	3.85	A	
	2.5	3.5	—	—	3.60	4.50	—	—	3.10	8.10	10.00	0.55	2.12	2.90	2.44	9.41	12.87	3.82	A	3.83	A	
	2.5	4.2	—	—	3.44	5.16	—	—	3.10	8.60	10.00	0.55	2.25	2.90	2.44	9.98	12.87	3.82	A	3.87	A	
	2.5	5.0	—	—	3.23	5.38	—	—	3.10	8.60	10.00	0.55	2.22	2.90	2.44	9.85	12.87	3.87	A	3.85	A	
	2.5	7.1	—	—	2.92	5.68	—	—	3.10	8.60	10.00	0.55	2.22	2.90	2.44	9.85	12.87	3.87	A	3.84	A	
	3.5	3.5	—	—	4.30	4.30	—	—	3.10	8.60	10.00	0.55	2.22	2.90	2.44	9.85	12.87	3.87	A	3.86	A	
	3.5	4.2	—	—	3.91	4.69	—	—	3.10	8.60	10.00	0.55	2.22	3.00	2.44	9.85	13.31	3.87	A	3.82	A	
	3.5	5.0	—	—	3.51	4.69	—	—	3.10	8.20	10.00	0.55	2.10	3.00	2.44	9.32	13.31	3.90	A	3.80	A	
	3.5	7.1	—	—	3.37	5.23	—	—	3.10	8.60	10.00	0.55	2.20	3.00	2.44	9.76	13.31	3.91	A	3.84	A	
	4.2	4.2	—	—	4.30	4.30	—	—	3.10	8.60	10.00	0.55	2.20	3.10	2.44	9.76	13.75	3.91	A	3.86	A	
	4.2	5.0	—	—	4.07	4.53	—	—	3.10	8.60	10.00	0.55	2.19	3.10	2.44	9.72	13.75	3.93	A	3.83	A	
	4.2	7.1	—	—	3.75	4.85	—	—	3.10	8.60	10.00	0.55	2.19	3.10	2.44	9.72	13.75	3.93	A	3.86	A	
	5.0	5.0	—	—	4.30	4.30	—	—	3.10	8.60	10.00	0.55	2.19	3.10	2.44	9.72	13.75	3.93	A	3.86	A	
	5.0	7.1	—	—	3.97	4.63	—	—	3.10	8.60	10.00	0.55	2.19	3.10	2.44	9.72	13.75	3.93	A	3.87	A	
	3	2.0	2.0	2.0	—	2.30	2.30	2.30	—	3.10	6.90	9.50	0.55	1.85	3.10	2.44	8.21	13.75	3.73	A	3.80	A
		2.0	2.0	2.5	—	2.30	2.30	3.60	—	3.10	8.20	10.00	0.55	2.16	3.10	2.44	9.58	13.75	3.80	A	3.80	A
		2.0	2.0	3.5	—	2.17	2.17	4.25	—	3.10	8.60	10.00	0.55	2.26	3.10	2.44	10.03	13.75	3.81	A	3.80	A
		2.0	2.0	4.2	—	1.98	1.98	4.64	—	3.10	8.60	10.00	0.55	2.25	3.10	2.44	9.98	13.75	3.82	A	3.80	A
		2.0	2.0	5.0	—	1.87	1.87	4.87	—	3.10	8.60	10.00	0.55	2.25	3.10	2.44	9.98	13.75	3.82	A	3.80	A
2.0		2.0	7.1	—	1.71	1.71	5.19	—	3.10	8.60	10.00	0.55	2.25	3.10	2.44	9.98	13.75	3.82	A	3.80	A	
2.0		2.5	2.5	—	2.08	3.26	3.26	—	3.10	8.60	10.00	0.55	2.25	3.10	2.44	9.98	13.75	3.82	A	3.80	A	
2.0		2.5	3.5	—	1.90	2.98	3.72	—	3.10	8.60	10.00	0.55	2.25	3.10	2.44	9.98	13.75	3.82	A	3.80	A	
2.0		2.5	4.2	—	1.75	2.74	4.11	—	3.10	8.60	10.00	0.55	2.25	3.10	2.44	9.98	13.75	3.82	A	3.80	A	
2.0		2.5	5.0	—	1.66	2.60	4.34	—	3.10	8.60	10.00	0.55	2.25	3.10	2.44	9.98	13.75	3.82	A	3.82	A	
2.0		2.5	7.1	—	1.53	2.40	4.67	—	3.10	8.60	10.00	0.55	2.25	3.10	2.44	9.98	13.75	3.82	A	3.82	A	
2.0		3.5	3.5	—	1.75	3.42	3.42	—	3.10	8.60	10.00	0.55	2.23	3.10	2.44	9.89	13.75	3.86	A	3.82	A	
2.0		3.5	4.2	—	1.62	3.17	3.81	—	3.10	8.60	10.00	0.55	2.23	3.10	2.44	9.89	13.75	3.86	A	3.82	A	
2.0		3.5	5.0	—	1.55	3.02	4.03	—	3.10	8.60	10.00	0.55	2.23	3.10	2.44	9.89	13.75	3.86	A	3.82	A	
2.0		3.5	7.1	—	1.43	2.80	4.36	—	3.10	8.60	10.00	0.55	2.23	3.10	2.44	9.89	13.75	3.86	A	3.82	A	
2.0		4.2	4.2	—	1.51	3.55	3.55	—	3.10	8.60	10.00	0.55	2.23	3.10	2.44	9.89	13.75	3.86	A	3.82	A	
2.0		4.2	5.0	—	1.44	3.39	3.77	—	3.10	8.60	10.00	0.55	2.23	3.10	2.44	9.89	13.75	3.86	A	3.82	A	
2.0		4.2	7.1	—	1.35	3.16	4.10	—	3.10	8.60	10.00	0.55	2.23	3.10	2.44	9.89	13.75	3.86	A	3.87	A	
2.5		2.5	2.5	—	2.87	2.87	2.87	—	3.10	8.60	10.00	0.55	2.23	3.10	2.44	9.89	13.75	3.86	A	3.87	A	
2.5		2.5	3.5	—	2.65	2.65	3.31	—	3.10	8.60	10.00	0.55	2.23	3.10	2.44	9.89	13.75	3.86	A	3.87	A	
2.5		2.5	4.2	—	2.46	2.46	3.69	—	3.10	8.60	10.00	0.55	2.23	3.10	2.44	9.89	13.75	3.86	A	3.87	A	
2.5		2.5	5.0	—	2.35	2.35	3.91	—	3.10	8.60	10.00	0.55	2.23	3.10	2.44	9.89	13.75	3.86	A	3.87	A	
2.5		2.5	7.1	—	2.18	2.18	4.24	—	3.10	8.60	10.00	0.55	2.23	3.10	2.44	9.89	13.75	3.86	A	3.90	A	
2.5		3.5	3.5	—	2.46	3.07	3.07	—	3.10	8.60	10.00	0.55	2.19	3.10	2.44	9.72	13.75	3.93	A	3.85	A	
2.5		3.5	4.2	—	2.29	2.87	3.44	—	3.10	8.60	10.00	0.55	2.19	3.10	2.44	9.72	13.75	3.93	A	3.85	A	
2.5		3.5	5.0	—	2.20	2.74	3.66	—	3.10	8.60	10.00	0.55	2.19	3.10	2.44	9.72	13.75	3.93	A	3.85	A	
2.5		3.5	7.1	—	2.05	2.56	3.99	—	3.10	8.60	10.00	0.55	2.18	3.10	2.44	9.67	13.75	3.94	A	3.85	A	
2.5		4.2	4.2	—	2.15	3.23	3.23	—	3.10	8.60	10.00	0.55	2.18	3.10	2.44	9.67	13.75	3.94	A	3.85	A	
2.5		4.2	5.0	—	2.06	3.10	3.44	—	3.10	8.60	10.00	0.55	2.18	3.10	2.44	9.67	13.75	3.94	A	3.85	A	
3.5		3.5	3.5	—	2.87	2.87	2.87	—	3.10	8.60	10.00	0.55	2.18	3.10	2.44	9.67	13.75	3.94	A	3.90	A	
3.5		3.5	4.2	—	2.69	2.69	3.23	—	3.10	8.60	10.00	0.55	2.18	3.10	2.44	9.67	13.75	3.94	A	3.90	A	
3.5		3.5	5.0	—	2.58	2.58	3.44	—	3.10	8.60	10.00	0.55	2.18	3.10	2.44	9.67	13.75	3.94	A	3.90	A	
4		2.0	2.0	2.0	2.0	2.15	2.15	2.15	2.15	3.10	8.60	10.00	0.55	2.25	3.10	2.44	9.98	13.75	3.82	A	3.85	A
		2.0	2.0	2.0	2.5	1.88	1.88	1.88	2.95	3.10	8.60	10.00	0.55	2.22	3.10	2.44	9.85	13.75	3.87	A	3.85	A
		2.0	2.0	2.0	3.5	1.74	1.74	1.74	3.39	3.10	8.60	10.00	0.55	2.22	3.10	2.44	9.85	13.75	3.87	A	3.85	A
		2.0	2.0	2.0	4.2	1.61	1.61	1.61	3.78	3.10	8.60	10.00	0.55	2.19	3.10	2.44	9.72	13.75	3.93	A	3.85	A
		2.0	2.0	2.0	5.0	1.53	1.53	1.53	4.00	3.10	8.60	10.00	0.55	2.19	3.10	2.44	9.72	13.75	3.93	A	3.85	A
		2.0	2.0	2.0	7.1	1.42	1.42	1.42	4.33	3.10	8.60	10.00	0.55	2.19	3.10	2.44	9.72	13.75	3.93	A	3.85	A
		2.0	2.0	2.5	2.5	1.68	1.68	2.62	2.62	3.10	8.60	10.00	0.55	2.19	3.10	2.44	9.72	13.75	3.93	A	3.85	A
		2.0	2.0	2.5	3.5	1.56	1.56	2.44	3.05	3.10	8.60	10.00	0.55	2.19	3.10	2						



4U85S2SR2FA

RAFFRESCAMENTO																						
Combinazioni				Potenza resa (kW)				Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			EER	Classe energ.	SEER	Classe energ.		
UI	A	B	C	D	A	B	C	D	min	nom	max	min	nom	max	min	nom	max	EER				
1	2.0	—	—	—	2.00	—	—	—	0.80	2.00	2.80	0.55	0.66	1.30	2.44	2.93	5.77	3.03	B	6.20	A++	
	2.5	—	—	—	2.60	—	—	—	0.80	2.60	3.90	0.55	0.86	1.34	2.44	3.82	5.93	3.02	B	6.20	A++	
	3.5	—	—	—	3.60	—	—	—	1.00	3.60	5.30	0.55	1.20	1.50	2.44	5.32	6.65	3.00	B	6.20	A++	
	4.2	—	—	—	4.40	—	—	—	1.30	4.40	5.00	0.55	1.40	1.90	2.44	6.21	8.43	3.14	B	6.20	A++	
	5.0	—	—	—	5.20	—	—	—	1.40	5.20	7.00	0.55	1.65	1.90	2.44	7.32	8.43	3.15	B	6.20	A++	
	7.1	—	—	—	6.50	—	—	—	1.50	6.50	7.40	0.55	2.00	3.00	2.44	8.87	13.31	3.25	A	6.20	A++	
	2.0	2.0	—	—	2.00	2.00	—	—	2.50	4.00	5.60	0.55	1.30	3.20	2.44	5.77	14.20	3.08	B	6.20	A++	
	2.0	2.5	—	—	2.00	2.60	—	—	2.50	4.60	6.70	0.55	1.50	3.20	2.44	6.65	14.20	3.07	B	6.20	A++	
	2.0	3.5	—	—	2.00	3.60	—	—	2.50	5.60	8.10	0.55	1.80	3.20	2.44	7.99	14.20	3.11	B	6.20	A++	
	2.0	4.2	—	—	2.00	4.40	—	—	2.50	6.40	7.80	0.55	2.05	3.20	2.44	9.09	14.20	3.12	B	6.20	A++	
2	2.0	5.0	—	—	2.00	5.20	—	—	2.50	7.20	9.30	0.55	2.28	3.20	2.44	10.12	14.20	3.16	B	6.20	A++	
	2.0	7.1	—	—	2.00	6.50	—	—	2.50	8.50	9.30	0.55	2.65	3.30	2.44	11.76	14.64	3.21	A	6.20	A++	
	2.5	2.5	—	—	2.60	2.60	—	—	2.50	5.20	7.80	0.55	1.60	3.30	2.44	7.10	14.64	3.25	A	6.20	A++	
	2.5	3.5	—	—	2.60	3.60	—	—	2.50	6.20	9.10	0.55	1.98	3.30	2.44	8.78	14.64	3.13	B	6.20	A++	
	2.5	4.2	—	—	2.60	4.40	—	—	2.50	7.00	9.30	0.55	2.20	3.30	2.44	9.76	14.64	3.18	B	6.20	A++	
	2.5	5.0	—	—	2.60	5.20	—	—	2.50	7.80	9.30	0.55	2.35	3.30	2.44	10.43	14.64	3.32	A	6.20	A++	
	2.5	7.1	—	—	2.43	6.07	—	—	2.50	8.50	9.30	0.55	2.60	3.30	2.44	11.54	14.64	3.27	A	6.20	A++	
	3.5	3.5	—	—	3.60	3.60	—	—	2.50	7.20	9.30	0.55	2.20	3.30	2.44	9.76	14.64	3.27	A	6.20	A++	
	3.5	4.2	—	—	3.60	4.40	—	—	2.50	8.00	9.30	0.55	2.42	3.30	2.44	10.74	14.64	3.31	A	6.20	A++	
	3.5	5.0	—	—	3.31	4.79	—	—	2.50	8.10	9.50	0.55	2.52	3.30	2.44	11.18	14.64	3.21	A	6.20	A++	
3	3.5	7.1	—	—	3.03	5.47	—	—	2.50	8.50	9.50	0.55	2.59	3.30	2.44	11.49	14.64	3.28	A	6.20	A++	
	4.2	4.2	—	—	4.25	4.25	—	—	2.50	8.50	9.50	0.55	2.59	3.30	2.44	11.49	14.64	3.28	A	6.20	A++	
	4.2	5.0	—	—	3.90	4.60	—	—	2.50	8.50	9.50	0.55	2.59	3.30	2.44	11.49	14.64	3.28	A	6.20	A++	
	4.2	7.1	—	—	3.43	5.07	—	—	2.50	8.50	9.50	0.55	2.58	3.30	2.44	11.45	14.64	3.29	A	6.20	A++	
	5.0	5.0	—	—	4.25	4.25	—	—	2.50	8.50	9.50	0.55	2.56	3.30	2.44	11.36	14.64	3.32	A	6.20	A++	
	5.0	7.1	—	—	3.78	4.72	—	—	2.50	8.50	9.50	0.55	2.55	3.30	2.44	11.31	14.64	3.33	A	6.20	A++	
	7.1	7.1	—	—	4.25	4.25	—	—	2.50	8.50	9.50	0.55	2.55	3.30	2.44	11.31	14.64	3.33	A	6.20	A++	
	2.0	2.0	2.0	—	2.00	2.00	2.00	—	3.00	6.00	9.50	0.55	1.85	3.50	2.44	8.21	15.53	3.24	A	6.70	A++	
	2.0	2.0	2.5	—	2.00	2.00	2.60	—	3.00	6.60	9.50	0.55	2.00	3.50	2.44	8.87	15.53	3.30	A	6.70	A++	
	2.0	2.0	3.5	—	2.00	2.00	3.60	—	3.00	7.60	9.50	0.55	2.30	3.50	2.44	10.20	15.53	3.30	A	6.70	A++	
4	2.0	2.0	4.2	—	2.00	2.00	4.40	—	3.20	8.40	9.50	0.55	2.56	3.50	2.44	11.36	15.53	3.28	A	6.70	A++	
	2.0	2.0	5.0	—	1.85	1.85	4.80	—	3.20	8.50	9.50	0.55	2.57	3.50	2.44	11.40	15.53	3.31	A	6.70	A++	
	2.0	2.0	7.1	—	1.62	1.62	5.26	—	3.20	8.50	9.50	0.55	2.57	3.50	2.44	11.40	15.53	3.31	A	6.70	A++	
	2.0	2.5	2.5	—	2.00	2.60	2.60	—	3.20	7.20	9.50	0.55	2.20	3.50	2.44	9.76	15.53	3.27	A	6.70	A++	
	2.0	2.5	3.5	—	2.00	2.60	3.60	—	3.20	8.20	9.50	0.55	2.50	3.50	2.44	11.09	15.53	3.28	A	6.70	A++	
	2.0	2.5	4.2	—	1.89	2.46	4.16	—	3.20	8.50	9.50	0.55	2.56	3.50	2.44	11.36	15.53	3.32	A	6.70	A++	
	2.0	2.5	5.0	—	1.73	2.26	4.51	—	3.20	8.50	9.50	0.55	2.56	3.50	2.44	11.36	15.53	3.32	A	6.70	A++	
	2.0	2.5	7.1	—	1.53	1.99	4.98	—	3.20	8.50	9.50	0.55	2.56	3.50	2.44	11.36	15.53	3.32	A	6.70	A++	
	2.0	3.5	3.5	—	1.85	3.33	3.33	—	3.20	8.50	9.50	0.55	2.56	3.50	2.44	11.36	15.53	3.32	A	6.70	A++	
	2.0	3.5	4.2	—	1.70	3.06	3.74	—	3.20	8.50	9.50	0.55	2.56	3.50	2.44	11.36	15.53	3.32	A	6.70	A++	

# Residenziale multisplit TABELLA COMBINAZIONI



4U85S2SR2FA

RISCALDAMENTO																								
Combinazioni				Potenza resa (kW)				Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			COP	Classe energ.	SCOP	Classe energ.				
UI	A	B	C	D	A	B	C	D	min	nom	max	min	nom	max	min	nom					max			
1	2.0	—	—	—	2.30	—	—	—	0.80	2.30	4.00	0.55	0.63	1.50	2.44	2.80	6.65	3.65	A	3.70	A			
	2	2.0	2.0	—	—	2.30	2.30	—	—	2.80	4.60	8.00	0.55	1.25	3.30	2.44	5.55	14.64	3.68	A	3.75	A		
		3	2.0	2.0	2.0	—	2.30	2.30	2.30	—	3.80	6.90	10.50	0.55	1.85	3.40	2.44	8.21	15.08	3.73	A	3.80	A	
			4	2.0	2.0	2.0	2.0	2.10	2.10	2.10	3.29	4.20	9.60	10.50	0.55	2.44	3.40	2.44	10.83	15.08	3.93	A	3.85	A

RESIDENZIALE MULTISPLIT

5U105S2SS2FA

RAFFRESCAMENTO																								
Combinazioni					Potenza resa (kW)					Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			EER	Classe energ.	SEER	Classe energ.		
UI	A	B	C	D	E	A	B	C	D	E	min	nom	max	min	nom	max	min	nom	max					
1	2.0	—	—	—	—	2.00	—	—	—	—	0.80	2.00	2.80	0.55	0.76	1.30	2.44	3.37	5.77	2.63	D	6.20	A++	
	2.5	—	—	—	—	2.60	—	—	—	—	0.80	2.60	3.90	0.55	0.98	1.34	2.44	4.35	5.93	2.65	D	6.20	A++	
	3.5	—	—	—	—	3.60	—	—	—	—	1.00	3.60	5.30	0.55	1.35	1.50	2.44	5.99	6.65	2.67	D	6.20	A++	
	4.2	—	—	—	—	4.40	—	—	—	—	1.30	4.40	5.00	0.55	1.59	1.90	2.44	7.05	8.43	2.77	D	6.20	A++	
	5.0	—	—	—	—	5.20	—	—	—	—	1.40	5.20	7.00	0.55	1.86	1.90	2.44	8.25	8.43	2.80	D	6.20	A++	
	7.1	—	—	—	—	6.50	—	—	—	—	1.50	6.50	7.40	0.55	2.25	3.00	2.44	9.98	13.31	2.89	C	6.20	A++	
	2.0	2.0	—	—	—	2.00	2.00	—	—	—	2.50	4.00	5.60	0.55	1.50	3.60	2.44	6.65	15.97	2.67	D	6.20	A++	
	2.0	2.5	—	—	—	2.00	2.60	—	—	—	2.50	4.60	6.70	0.55	1.67	3.60	2.44	7.41	15.97	2.75	D	6.20	A++	
	2.0	3.5	—	—	—	2.00	3.60	—	—	—	2.50	5.60	8.10	0.55	2.03	3.60	2.44	9.01	15.97	2.76	D	6.20	A++	
	2.0	4.2	—	—	—	2.00	4.40	—	—	—	2.50	6.40	7.80	0.55	2.30	3.60	2.44	10.20	15.97	2.78	D	6.20	A++	
2	2.0	5.0	—	—	—	2.00	5.20	—	—	—	2.50	7.20	9.30	0.55	2.58	3.60	2.44	11.45	15.97	2.79	D	6.20	A++	
	2.0	7.1	—	—	—	2.00	6.50	—	—	—	2.50	8.50	9.30	0.55	3.02	3.60	2.44	13.40	15.97	2.81	C	6.20	A++	
	2.5	2.5	—	—	—	2.60	2.60	—	—	—	2.50	5.20	7.80	0.55	1.90	3.60	2.44	8.43	15.97	2.74	D	6.20	A++	
	2.5	3.5	—	—	—	2.60	3.60	—	—	—	2.50	6.20	9.10	0.55	2.24	3.60	2.44	9.94	15.97	2.77	D	6.20	A++	
	2.5	4.2	—	—	—	2.60	4.40	—	—	—	2.50	7.00	9.30	0.55	2.52	3.60	2.44	11.18	15.97	2.78	D	6.20	A++	
	2.5	5.0	—	—	—	2.60	5.20	—	—	—	2.50	7.80	9.30	0.55	2.79	3.60	2.44	12.38	15.97	2.80	D	6.20	A++	
	2.5	7.1	—	—	—	2.60	6.50	—	—	—	2.50	9.10	9.30	0.55	3.17	3.60	2.44	14.06	15.97	2.87	C	6.20	A++	
	3.5	3.5	—	—	—	3.60	3.60	—	—	—	2.50	7.20	9.30	0.55	2.58	3.60	2.44	11.45	15.97	2.79	D	6.20	A++	
	3.5	4.2	—	—	—	3.60	4.40	—	—	—	2.50	8.00	9.30	0.55	2.85	3.60	2.44	12.64	15.97	2.81	C	6.20	A++	
	3.5	5.0	—	—	—	3.60	5.20	—	—	—	2.50	8.80	10.00	0.55	3.10	3.60	2.44	13.75	15.97	2.84	C	6.20	A++	
	3.5	7.1	—	—	—	3.56	6.44	—	—	—	2.50	10.00	11.00	0.55	3.48	3.60	2.44	15.44	15.97	2.87	C	6.20	A++	
	4.2	4.2	—	—	—	4.40	4.40	—	—	—	2.50	8.80	10.00	0.55	3.09	3.60	2.44	13.71	15.97	2.85	C	6.20	A++	
	4.2	5.0	—	—	—	4.40	5.20	—	—	—	2.50	9.60	10.50	0.55	3.38	3.60	2.44	15.00	15.97	2.84	C	6.20	A++	
	4.2	7.1	—	—	—	4.04	5.96	—	—	—	2.50	10.00	11.00	0.55	3.47	3.60	2.44	15.39	15.97	2.88	C	6.20	A++	
	5.0	5.0	—	—	—	5.00	5.00	—	—	—	2.50	10.00	11.00	0.55	3.50	3.60	2.44	15.53	15.97	2.86	C	6.20	A++	
	5.0	7.1	—	—	—	4.44	5.56	—	—	—	2.50	10.00	11.00	0.55	3.50	3.60	2.44	15.53	15.97	2.86	C	6.20	A++	
	7.1	7.1	—	—	—	5.00	5.00	—	—	—	2.50	10.00	11.00	0.55	3.45	3.60	2.44	15.31	15.97	2.90	C	6.20	A++	
	3	2.0	2.0	2.0	—	—	2.00	2.00	2.00	—	—	3.00	6.00	9.50	0.55	2.20	3.80	2.44	9.76	16.86	2.73	D	6.70	A++
		2.0	2.0	2.5	—	—	2.00	2.00	2.60	—	—	3.00	6.60	9.50	0.55	2.40	3.80	2.44	10.65	16.86	2.75	D	6.70	A++
		2.0	2.0	3.5	—	—	2.00	2.00	3.60	—	—	3.00	7.60	9.50	0.55	2.75	3.80	2.44	12.20	16.86	2.76	D	6.70	A++
		2.0	2.0	4.2	—	—	2.00	2.00	4.40	—	—	3.20	8.40	9.50	0.55	3.00	3.80	2.44	13.31	16.86	2.80	C	6.70	A++
		2.0	2.0	5.0	—	—	2.00	2.00	5.20	—	—	3.20	9.20	10.00	0.55	3.20	3.80	2.44	14.20	16.86	2.88	C	6.70	A++
		2.0	2.0	7.1	—	—	1.90	1.90	6.19	—	—	3.20	10.00	11.00	0.55	3.45	4.10	2.44	15.31	18.19	2.90	C	6.70	A++
		2.0	2.5	2.5	—	—	2.00	2.60	2.60	—	—	3.20	7.20	9.50	0.55	2.60	3.80	2.44	11.54	16.86	2.77	D	6.70	A++
		2.0	2.5	3.5	—	—	2.00	2.60	3.60	—	—	3.20	8.20	9.50	0.55	2.93	3.80	2.44	13.00	16.86	2.80	D	6.70	A++
		2.0	2.5	4.2	—	—	2.00	2.60	4.40	—	—	3.20	9.00	10.00	0.55	3.20	3.80	2.44	14.20	16.86	2.81	C	6.70	A++
2.0		2.5	5.0	—	—	2.00	2.60	5.20	—	—	3.20	9.80	11.00	0.55	3.44	3.80	2.44	15.26	16.86	2.85	C	6.70	A++	
2.0		2.5	7.1	—	—	1.80	2.34	5.86	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.0		3.5	3.5	—	—	2.00	3.60	3.60	—	—	3.20	9.20	11.00	0.55	3.38	3.80	2.44	15.00	16.86	2.72	D	6.70	A++	
2.0		3.5	4.2	—	—	2.00	3.60	4.40	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.0		3.5	5.0	—	—	1.85	3.33	4.81	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.0		3.5	7.1	—	—	1.65	2.98	5.37	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.0		4.2	4.2	—	—	1.85	4.07	4.07	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.0		4.2	5.0	—	—	1.72	3.79	4.48	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.0		4.2	7.1	—	—	1.55	3.41	5.04	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.0		5.0	5.0	—	—	1.61	4.19	4.19	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.0		5.0	7.1	—	—	1.46	3.80	4.74	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.5		2.5	2.5	—	—	2.60	2.60	2.60	—	—	3.20	7.80	9.50	0.55	2.78	3.80	2.44	12.33	16.86	2.81	C	6.72	A++	
2.5		2.5	3.5	—	—	2.60	2.60	3.60	—	—	3.20	8.80	10.00	0.55	3.14	3.80	2.44	13.93	16.86	2.80	C	6.72	A++	
2.5		2.5	4.2	—	—	2.60	2.60	4.40	—	—	3.20	9.60	11.00	0.55	3.40	3.80	2.44	15.08	16.86	2.82	C	6.74	A++	
2.5		2.5	5.0	—	—	2.50	2.50	5.00	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.74	A++	
2.5		2.5	7.1	—	—	2.22	2.22	5.56	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.5		3.5	3.5	—	—	2.60	3.60	3.60	—	—	3.20	9.80	11.00	0.55	3.45	3.80	2.44	15.31	16.86	2.84	C	6.73	A++	
2.5		3.5	4.2	—	—	2.45	3.40	4.15	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.5		3.5	5.0	—	—	2.28	3.16	4.56	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.5		3.5	7.1	—	—	2.05	2.83	5.12	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.5		4.2	4.2	—	—	2.28	3.86	3.86	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.5		4.2	5.0	—	—	2.13	3.61	4.26	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.5		4.2	7.1	—	—	1.93	3.26	4.81	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.5		5.0	5.0	—	—	2.00	4.00	4.00	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
2.5		5.0	7.1	—	—	1.82	3.64	4.55	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.70	A++	
3.5		3.5	3.5	—	—	3.33	3.33	3.33	—	—	3.20	10.00	11.00	0.55	3.50	4.10	2.44	15.53	18.19	2.86	C	6.75	A++	
3.5		3.5	4.2	—	—	3.10	3.10	3.79	—	—	3.20	10.00	11.00											



5U10S2S2FA

RAFFRESCAMENTO																								
Combinazioni					Potenza resa (kW)				Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			EER	Classe energ.	SEER	Classe energ.			
UI	A	B	C	D	E	A	B	C	D	E	min	nom	max	min	nom	max	min	nom	max					
4	2.0	2.0	2.0	2.0	—	2.00	2.00	2.00	2.00	—	3.20	8.00	11.00	0.55	2.80	4.00	2.44	12.42	17.75	2.86	C	6.80	A++	
	2.0	2.0	2.0	2.5	—	2.00	2.00	2.00	2.60	—	3.20	8.60	11.00	0.55	3.00	4.00	2.44	13.31	17.75	2.87	C	6.80	A++	
	2.0	2.0	2.0	3.5	—	2.00	2.00	2.00	3.60	—	3.20	9.60	11.00	0.55	3.30	4.00	2.44	14.64	17.75	2.91	C	6.80	A++	
	2.0	2.0	2.0	4.2	—	1.92	1.92	1.92	4.23	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.80	A++	
	2.0	2.0	2.0	5.0	—	1.79	1.79	1.79	4.64	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.80	A++	
	2.0	2.0	2.0	7.1	—	1.60	1.60	1.60	5.20	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.70	A++	
	2.0	2.0	2.0	2.5	2.5	—	2.00	2.00	2.60	2.60	—	3.20	9.20	11.00	0.55	3.20	4.00	2.44	14.20	17.75	2.88	C	6.80	A++
	2.0	2.0	2.0	2.5	3.5	—	1.96	1.96	2.55	3.53	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.80	A++
	2.0	2.0	2.0	2.5	4.2	—	1.82	1.82	2.36	4.00	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.80	A++
	2.0	2.0	2.0	2.5	5.0	—	1.69	1.69	2.20	4.41	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.80	A++
	2.0	2.0	2.0	2.5	7.1	—	1.53	1.53	1.98	4.96	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.70	A++
	2.0	2.0	2.0	3.5	3.5	—	1.79	1.79	3.21	3.21	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.80	A++
	2.0	2.0	2.0	3.5	4.2	—	1.67	1.67	3.00	3.67	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.70	A++
	2.0	2.0	2.0	3.5	5.0	—	1.56	1.56	2.81	4.06	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.70	A++
	2.0	2.0	2.0	3.5	7.1	—	1.42	1.42	2.55	4.61	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.70	A++
	2.0	2.0	2.0	4.2	4.2	—	1.56	1.56	3.44	3.44	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.90	A++
	2.0	2.0	2.0	4.2	5.0	—	1.47	1.47	3.24	3.82	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.90	A++
	2.0	2.0	2.0	5.0	5.0	—	1.39	1.39	3.61	3.61	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.90	A++
	2.0	2.5	2.5	2.5	2.5	—	2.00	2.60	2.60	2.60	—	3.20	9.80	11.00	0.55	3.37	4.00	2.44	14.95	17.75	2.91	C	6.90	A++
	2.0	2.5	2.5	2.5	3.5	—	1.85	2.41	2.41	3.33	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.90	A++
	2.0	2.5	2.5	2.5	4.2	—	1.72	2.24	2.24	3.79	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.90	A++
	2.0	2.5	2.5	2.5	5.0	—	1.61	2.10	2.10	4.19	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.90	A++
	2.0	2.5	2.5	2.5	7.1	—	1.46	1.90	1.90	4.74	—	3.20	10.00	11.00	0.55	3.40	4.10	2.44	15.08	18.19	2.94	C	6.90	A++
	2.0	2.5	2.5	3.5	3.5	—	1.69	2.20	3.05	3.05	—	3.20	10.00	11.00	0.55	3.38	4.10	2.44	15.00	18.19	2.96	C	6.90	A++
	2.0	2.5	2.5	3.5	4.2	—	1.59	2.06	2.86	3.49	—	3.20	10.00	11.00	0.55	3.38	4.10	2.44	15.00	18.19	2.96	C	6.90	A++
	2.0	2.5	2.5	3.5	5.0	—	1.49	1.94	2.69	3.88	—	3.20	10.00	11.00	0.55	3.38	4.10	2.44	15.00	18.19	2.96	C	6.90	A++
	2.0	2.5	2.5	4.2	4.2	—	1.49	1.94	3.28	3.28	—	3.20	10.00	11.00	0.55	3.38	4.10	2.44	15.00	18.19	2.96	C	6.90	A++
	2.0	2.5	2.5	4.2	5.0	—	1.41	1.83	3.10	3.66	—	3.20	10.00	11.00	0.55	3.38	4.10	2.44	15.00	18.19	2.96	C	6.90	A++
	2.0	2.5	2.5	5.0	5.0	—	1.33	1.73	3.47	3.47	—	3.20	10.00	11.00	0.55	3.38	4.10	2.44	15.00	18.19	2.96	C	6.90	A++
	2.0	3.5	3.5	3.5	3.5	—	1.56	2.81	2.81	2.81	—	3.20	10.00	11.00	0.55	3.38	4.10	2.44	15.00	18.19	2.96	C	6.90	A++
	2.0	3.5	3.5	3.5	4.2	—	1.47	2.65	2.65	3.24	—	3.20	10.00	11.00	0.55	3.38	4.10	2.44	15.00	18.19	2.96	C	6.90	A++
	2.0	3.5	3.5	3.5	5.0	—	1.39	2.50	2.50	3.61	—	3.20	10.00	11.00	0.55	3.36	4.10	2.44	14.91	18.19	2.98	C	6.90	A++
	2.0	3.5	3.5	4.2	4.2	—	1.39	2.50	3.06	3.06	—	3.20	10.00	11.00	0.55	3.36	4.10	2.44	14.91	18.19	2.98	C	6.90	A++
	2.0	3.5	3.5	4.2	5.0	—	1.32	2.37	2.89	3.42	—	3.20	10.00	11.00	0.55	3.36	4.10	2.44	14.91	18.19	2.98	C	6.90	A++
	2.0	4.2	4.2	4.2	4.2	—	1.32	2.89	2.89	2.89	—	3.20	10.00	11.00	0.55	3.36	4.10	2.44	14.91	18.19	2.98	C	6.90	A++
	2.5	2.5	2.5	2.5	2.5	—	2.50	2.50	2.50	2.50	—	3.20	10.00	11.00	0.55	3.36	4.10	2.44	14.91	18.19	2.98	C	6.90	A++
	2.5	2.5	2.5	2.5	3.5	—	2.28	2.28	2.28	3.16	—	3.20	10.00	11.00	0.55	3.36	4.10	2.44	14.91	18.19	2.98	C	6.90	A++
	2.5	2.5	2.5	2.5	4.2	—	2.13	2.13	2.13	3.61	—	3.20	10.00	11.00	0.55	3.36	4.10	2.44	14.91	18.19	2.98	C	6.90	A++
	2.5	2.5	2.5	2.5	5.0	—	2.00	2.00	2.00	4.00	—	3.20	10.00	11.00	0.55	3.36	4.10	2.44	14.91	18.19	2.98	C	6.90	A++
	2.5	2.5	2.5	2.5	7.1	—	1.82	1.82	1.82	4.55	—	3.20	10.00	11.00	0.55	3.36	4.10	2.44	14.91	18.19	2.98	C	6.90	A++
	2.5	2.5	2.5	3.5	3.5	—	2.10	2.10	2.90	2.90	—	3.20	10.00	11.00	0.55	3.36	4.10	2.44	14.91	18.19	2.98	C	6.90	A++
	2.5	2.5	2.5	3.5	4.2	—	1.97	1.97	2.73	3.33	—	3.20	10.00	11.00	0.55	3.36	4.10	2.44	14.91	18.19	2.98	C	7.00	A++
	2.5	2.5	2.5	3.5	5.0	—	1.86	1.86	2.57	3.71	—	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++
	2.5	2.5	2.5	4.2	4.2	—	1.86	1.86	3.14	3.14	—	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++
	2.5	2.5	2.5	4.2	5.0	—	1.76	1.76	2.97	3.51	—	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++
2.5	2.5	2.5	5.0	5.0	—	1.67	1.67	3.33	3.33	—	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++	
2.5	3.5	3.5	3.5	3.5	—	1.94	2.69	2.69	2.69	—	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++	
2.5	3.5	3.5	3.5	4.2	—	1.83	2.54	2.54	3.10	—	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++	
2.5	3.5	3.5	3.5	5.0	—	1.73	2.40	2.40	3.47	—	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++	
2.5	3.5	3.5	4.2	4.2	—	1.73	2.40	2.93	2.93	—	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++	
3.5	3.5	3.5	3.5	3.5	—	2.50	2.50	2.50	2.50	—	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++	
3.5	3.5	3.5	3.5	4.2	—	2.37	2.37	2.37	2.89	—	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++	
5	2.0	2.0	2.0	2.0	2.0	2.00	2.00	2.00	2.00	2.00	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++	
	2.0	2.0	2.0	2.0	2.5	1.89	1.89	1.89	1.89	2.45	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++	
	2.0	2.0	2.0	2.0	3.5	1.72	1.72	1.72	1.72	3.10	3.20	10.00	11.00	0.55	3.33	4.10	2.44	14.77	18.19	3.00	B	7.00	A++	
	2.0	2.0																						

5U105S2SS2FA

RISCALDAMENTO																								
Combinazioni					Potenza resa (kW)					Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			COP	Classe energ.	SCOP	Classe energ.		
UI	A	B	C	D	E	A	B	C	D	E	min	nom	max	min	nom	max	min	nom	max					
	1	2.0	—	—	—	—	2.30	—	—	—	—	0.80	2.30	4.00	0.55	0.66	1.50	2.44	2.93	6.65	3.48	B	3.70	A
2.5		—	—	—	—	3.60	—	—	—	—	0.80	3.60	6.00	0.55	1.03	1.40	2.44	4.57	6.21	3.50	B	3.70	A	
3.5		—	—	—	—	4.50	—	—	—	—	1.00	4.50	6.00	0.55	1.27	1.50	2.44	5.63	6.65	3.54	B	3.70	A	
4.2		—	—	—	—	5.40	—	—	—	—	1.50	5.40	6.00	0.55	1.50	1.90	2.44	6.65	8.43	3.60	A	3.70	A	
5.0		—	—	—	—	6.00	—	—	—	—	1.50	6.00	8.00	0.55	1.65	2.60	2.44	7.32	11.54	3.64	A	3.70	A	
7.1		—	—	—	—	7.00	—	—	—	—	1.50	7.00	8.60	0.55	1.90	2.60	2.44	8.43	11.54	3.68	A	3.70	A	
2	2.0	2.0	—	—	—	2.30	2.30	—	—	—	2.80	4.60	8.00	0.55	1.30	3.30	2.44	5.77	14.64	3.54	B	3.75	A	
	2.0	2.5	—	—	—	2.30	3.60	—	—	—	3.00	5.90	10.00	0.55	1.66	3.30	2.44	7.36	14.64	3.55	B	3.75	A	
	2.0	3.5	—	—	—	2.30	4.50	—	—	—	3.20	6.80	10.00	0.55	1.90	3.30	2.44	8.43	14.64	3.58	B	3.75	A	
	2.0	4.2	—	—	—	2.30	5.40	—	—	—	3.40	7.70	10.00	0.55	2.15	3.30	2.44	9.54	14.64	3.58	B	3.80	A	
	2.0	5.0	—	—	—	2.30	6.00	—	—	—	3.80	8.30	11.50	0.55	2.29	3.30	2.44	10.16	14.64	3.62	A	3.80	A	
	2.0	7.1	—	—	—	2.30	7.00	—	—	—	4.00	9.30	11.50	0.55	2.55	3.30	2.44	11.31	14.64	3.65	A	3.85	A	
	2.5	2.5	—	—	—	3.60	3.60	—	—	—	3.40	7.20	10.50	0.55	2.02	3.30	2.44	8.96	14.64	3.56	B	3.85	A	
	2.5	3.5	—	—	—	3.60	4.50	—	—	—	3.80	8.10	10.50	0.55	2.26	3.30	2.44	10.03	14.64	3.58	B	3.83	A	
	2.5	4.2	—	—	—	3.60	5.40	—	—	—	4.00	9.00	10.50	0.55	2.50	3.30	2.44	11.09	14.64	3.60	B	3.87	A	
	2.5	5.0	—	—	—	3.60	6.00	—	—	—	4.40	9.60	10.50	0.55	2.64	3.30	2.44	11.71	14.64	3.64	A	3.85	A	
	2.5	7.1	—	—	—	3.57	6.93	—	—	—	4.40	10.50	11.00	0.55	2.85	3.30	2.44	12.64	14.64	3.68	A	3.84	A	
	3.5	3.5	—	—	—	4.50	4.50	—	—	—	4.00	9.00	10.50	0.55	2.50	3.30	2.44	11.09	14.64	3.60	B	3.86	A	
	3.5	4.2	—	—	—	4.50	5.40	—	—	—	4.40	9.90	10.50	0.55	2.74	3.30	2.44	12.16	14.64	3.61	A	3.82	A	
	3.5	5.0	—	—	—	4.50	6.00	—	—	—	4.40	10.50	11.50	0.55	2.88	3.30	2.44	12.78	14.64	3.65	A	3.80	A	
	3.5	7.1	—	—	—	4.11	6.39	—	—	—	4.40	10.50	11.50	0.55	2.88	3.30	2.44	12.78	14.64	3.65	A	3.84	A	
	4.2	4.2	—	—	—	5.25	5.25	—	—	—	4.40	10.50	11.50	0.55	2.88	3.30	2.44	12.78	14.64	3.65	A	3.86	A	
	4.2	5.0	—	—	—	4.97	5.53	—	—	—	4.40	10.50	11.50	0.55	2.88	3.30	2.44	12.78	14.64	3.65	A	3.83	A	
	4.2	7.1	—	—	—	4.57	5.93	—	—	—	4.40	10.50	11.50	0.55	2.88	3.30	2.44	12.78	14.64	3.65	A	3.86	A	
	5.0	5.0	—	—	—	5.25	5.25	—	—	—	4.40	10.50	11.50	0.55	2.91	3.30	2.44	12.91	14.64	3.61	A	3.80	A	
	5.0	7.1	—	—	—	4.85	5.65	—	—	—	4.40	10.50	11.50	0.55	2.88	3.30	2.44	12.78	14.64	3.65	A	3.87	A	
	7.1	7.1	—	—	—	5.25	5.25	—	—	—	4.40	10.50	11.50	0.55	2.88	3.30	2.44	12.78	14.64	3.65	A	3.85	A	
	3	2.0	2.0	2.0	—	—	2.30	2.30	2.30	—	—	3.80	6.90	11.50	0.55	1.93	3.40	2.44	8.56	15.08	3.58	B	3.80	A
		2.0	2.0	2.5	—	—	2.30	2.30	3.60	—	—	4.00	8.20	11.50	0.55	2.28	3.40	2.44	10.12	15.08	3.60	B	3.80	A
		2.0	2.0	3.5	—	—	2.30	2.30	4.50	—	—	4.20	9.10	11.50	0.55	2.50	3.40	2.44	11.09	15.08	3.64	A	3.80	A
2.0		2.0	4.2	—	—	2.30	2.30	5.40	—	—	4.40	10.00	11.50	0.55	2.73	3.40	2.44	12.11	15.08	3.66	A	3.80	A	
2.0		2.0	5.0	—	—	2.28	2.28	5.94	—	—	4.40	10.50	11.50	0.55	2.88	3.40	2.44	12.78	15.08	3.65	A	3.80	A	
2.0		2.0	7.1	—	—	2.08	2.08	6.34	—	—	4.40	10.50	11.50	0.55	2.88	3.40	2.44	12.78	15.08	3.65	A	3.80	A	
2.0		2.5	2.5	—	—	2.30	3.60	3.60	—	—	4.40	9.50	11.50	0.55	2.63	3.40	2.44	11.67	15.08	3.61	A	3.80	A	
2.0		2.5	3.5	—	—	2.30	3.60	4.50	—	—	4.40	10.40	11.50	0.55	2.88	3.40	2.44	12.78	15.08	3.61	A	3.80	A	
2.0		2.5	4.2	—	—	2.14	3.35	5.02	—	—	4.40	10.50	11.50	0.55	2.88	3.40	2.44	12.78	15.08	3.65	A	3.80	A	
2.0		2.5	5.0	—	—	2.03	3.18	5.29	—	—	4.40	10.50	11.50	0.55	2.88	3.40	2.44	12.78	15.08	3.65	A	3.82	A	
2.0		2.5	7.1	—	—	1.87	2.93	5.70	—	—	4.40	10.50	11.50	0.55	2.88	3.40	2.44	12.78	15.08	3.65	A	3.82	A	
2.0		3.5	3.5	—	—	2.14	4.18	4.18	—	—	4.40	10.50	11.50	0.55	2.88	3.40	2.44	12.78	15.08	3.65	A	3.82	A	
2.0		3.5	4.2	—	—	1.98	3.87	4.65	—	—	4.40	10.50	11.50	0.55	2.88	3.40	2.44	12.78	15.08	3.65	A	3.82	A	
2.0		3.5	5.0	—	—	1.89	3.69	4.92	—	—	4.40	10.50	11.50	0.55	2.88	3.40	2.44	12.78	15.08	3.65	A	3.82	A	
2.0		3.5	7.1	—	—	1.75	3.42	5.33	—	—	4.40	10.50	11.50	0.55	2.86	3.40	2.44	12.69	15.08	3.67	A	3.82	A	
2.0		4.2	4.2	—	—	1.84	4.33	4.33	—	—	4.40	10.50	11.50	0.55	2.86	3.40	2.44	12.69	15.08	3.67	A	3.82	A	
2.0		4.2	5.0	—	—	1.76	4.14	4.60	—	—	4.40	10.50	11.50	0.55	2.86	3.40	2.44	12.69	15.08	3.67	A	3.82	A	
2.0		4.2	7.1	—	—	1.64	3.86	5.00	—	—	4.40	10.50	11.50	0.55	2.86	3.40	2.44	12.69	15.08	3.67	A	3.87	A	
2.0		5.0	5.0	—	—	1.69	4.41	4.41	—	—	4.40	10.50	11.50	0.55	2.86	3.40	2.44	12.69	15.08	3.67	A	3.87	A	
2.0		5.0	7.1	—	—	1.58	4.12	4.80	—	—	4.40	10.50	11.50	0.55	2.86	3.40	2.44	12.69	15.08	3.67	A	3.87	A	
2.5		2.5	2.5	—	—	3.50	3.50	3.50	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.87	A	
2.5		2.5	3.5	—	—	3.23	3.23	4.04	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.87	A	
2.5		2.5	4.2	—	—	3.00	3.00	4.50	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.87	A	
2.5		2.5	5.0	—	—	2.86	2.86	4.77	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.87	A	
2.5		2.5	7.1	—	—	2.66	2.66	5.18	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.90	A	
2.5		3.5	3.5	—	—	3.00	3.75	3.75	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.85	A	
2.5		3.5	4.2	—	—	2.80	3.50	4.20	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.85	A	
2.5		3.5	5.0	—	—	2.68	3.35	4.47	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.85	A	
2.5		3.5	7.1	—	—	2.50	3.13	4.87	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.85	A	
2.5		4.2	4.2	—	—	2.62	3.94	3.94	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.85	A	
2.5		4.2	5.0	—	—	2.52	3.78	4.20	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.85	A	
2.5		4.2	7.1	—	—	2.36	3.54	4.59	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.85	A	
2.5		5.0	5.0	—	—	2.42	4.04	4.04	—	—	4.40	10.50	11.50	0.55	2.85	3.40	2.44	12.64	15.08	3.68	A	3.85	A	
2.5		5.0	7.1	—																				

5U10S2S2FA

RISCALDAMENTO																							
UI	Combinazioni				Potenza resa (kW)				Potenza resa sistema (kW)			Potenza assorbita (kW)			Corrente assorbita (A)			COP	Classe energ.	SCOP	Classe energ.		
	A	B	C	D	E	A	B	C	D	E	min	nom	max	min	nom	max	min					nom	max
4	2.0	2.0	2.0	2.0	—	2.30	2.30	2.30	2.30	—	4.20	9.20	11.50	0.55	2.55	3.40	2.44	11.31	15.08	3.61	A	3.85	A
	2.0	2.0	2.0	2.5	—	2.30	2.30	2.30	3.60	—	4.20	10.50	11.50	0.55	2.84	3.40	2.44	12.60	15.08	3.70	A	3.85	A
	2.0	2.0	2.0	3.5	—	2.12	2.12	2.12	4.14	—	4.40	10.50	11.50	0.55	2.84	3.40	2.44	12.60	15.08	3.70	A	3.85	A
	2.0	2.0	2.0	4.2	—	1.96	1.96	1.96	4.61	—	4.40	10.50	11.50	0.55	2.84	3.40	2.44	12.60	15.08	3.70	A	3.85	A
	2.0	2.0	2.0	5.0	—	1.87	1.87	1.87	4.88	—	4.40	10.50	11.50	0.55	2.84	3.40	2.44	12.60	15.08	3.70	A	3.85	A
	2.0	2.0	2.0	7.1	—	1.74	1.74	1.74	5.29	—	4.40	10.50	11.50	0.55	2.84	3.40	2.44	12.60	15.08	3.70	A	3.85	A
	2.0	2.0	2.5	2.5	—	2.05	2.05	3.20	3.20	—	4.40	10.50	11.50	0.55	2.84	3.40	2.44	12.60	15.08	3.70	A	3.85	A
	2.0	2.0	2.5	3.5	—	1.90	1.90	2.98	3.72	—	4.40	10.50	11.50	0.55	2.83	3.40	2.44	12.56	15.08	3.71	A	3.85	A
	2.0	2.0	2.5	4.2	—	1.78	1.78	2.78	4.17	—	4.40	10.50	11.50	0.55	2.83	3.40	2.44	12.56	15.08	3.71	A	3.90	A
	2.0	2.0	2.5	5.0	—	1.70	1.70	2.66	4.44	—	4.40	10.50	11.50	0.55	2.83	3.40	2.44	12.56	15.08	3.71	A	3.90	A
	2.0	2.0	2.5	7.1	—	1.59	1.59	2.49	4.84	—	4.40	10.50	11.50	0.55	2.83	3.40	2.44	12.56	15.08	3.71	A	3.90	A
	2.0	2.0	3.5	3.5	—	1.78	1.78	3.47	3.47	—	4.40	10.50	11.50	0.55	2.83	3.40	2.44	12.56	15.08	3.71	A	3.90	A
	2.0	2.0	3.5	4.2	—	1.67	1.67	3.26	3.91	—	4.40	10.50	11.50	0.55	2.83	3.40	2.44	12.56	15.08	3.71	A	3.90	A
	2.0	2.0	3.5	5.0	—	1.60	1.60	3.13	4.17	—	4.40	10.50	11.50	0.55	2.81	3.40	2.44	12.47	15.08	3.74	A	3.90	A
	2.0	2.0	3.5	7.1	—	1.50	1.50	2.93	4.57	—	4.40	10.50	11.50	0.55	2.81	3.40	2.44	12.47	15.08	3.74	A	3.90	A
	2.0	2.0	4.2	4.2	—	1.57	1.57	3.68	3.68	—	4.40	10.50	11.50	0.55	2.81	3.40	2.44	12.47	15.08	3.74	A	3.90	A
	2.0	2.0	4.2	5.0	—	1.51	1.51	3.54	3.94	—	4.40	10.50	11.50	0.55	2.81	3.40	2.44	12.47	15.08	3.74	A	3.90	A
	2.0	2.0	5.0	5.0	—	1.45	1.45	3.80	3.80	—	4.40	10.50	11.50	0.55	2.81	3.40	2.44	12.47	15.08	3.74	A	3.90	A
	2.0	2.5	2.5	2.5	—	1.84	2.89	2.89	2.89	—	4.40	10.50	11.50	0.55	2.81	3.40	2.44	12.47	15.08	3.74	A	3.90	A
	2.0	2.5	2.5	3.5	—	1.73	2.70	2.70	3.38	—	4.40	10.50	11.50	0.55	2.80	3.40	2.44	12.42	15.08	3.75	A	3.90	A
	2.0	2.5	2.5	4.2	—	1.62	2.54	2.54	3.81	—	4.40	10.50	11.50	0.55	2.80	3.40	2.44	12.42	15.08	3.75	A	3.95	A
	2.0	2.5	2.5	5.0	—	1.56	2.44	2.44	4.06	—	4.40	10.50	11.50	0.55	2.80	3.40	2.44	12.42	15.08	3.75	A	3.95	A
	2.0	2.5	2.5	7.1	—	1.46	2.29	2.29	4.45	—	4.40	10.50	11.50	0.55	2.80	3.40	2.44	12.42	15.08	3.75	A	3.95	A
	2.0	2.5	3.5	3.5	—	1.62	2.54	3.17	3.17	—	4.40	10.50	11.50	0.55	2.80	3.40	2.44	12.42	15.08	3.75	A	3.95	A
	2.0	2.5	3.5	4.2	—	1.53	2.39	2.99	3.59	—	4.40	10.50	11.50	0.55	2.80	3.40	2.44	12.42	15.08	3.75	A	3.95	A
	2.0	2.5	3.5	5.0	—	1.47	2.30	2.88	3.84	—	4.40	10.50	11.50	0.55	2.80	3.40	2.44	12.42	15.08	3.75	A	3.95	A
	2.0	2.5	4.2	4.2	—	1.45	2.26	3.40	3.40	—	4.40	10.50	11.50	0.55	2.80	3.40	2.44	12.42	15.08	3.75	A	3.95	A
	2.0	2.5	4.2	5.0	—	1.40	2.18	3.28	3.64	—	4.40	10.50	11.50	0.55	2.80	3.40	2.44	12.42	15.08	3.75	A	3.95	A
	2.0	2.5	5.0	5.0	—	1.35	2.11	3.52	3.52	—	4.40	10.50	11.50	0.55	2.78	3.40	2.44	12.33	15.08	3.78	A	3.95	A
	2.0	3.5	3.5	3.5	—	1.53	2.99	2.99	2.99	—	4.40	10.50	11.50	0.55	2.78	3.40	2.44	12.33	15.08	3.78	A	3.95	A
	2.0	3.5	3.5	4.2	—	1.45	2.83	2.83	3.40	—	4.40	10.50	11.50	0.55	2.78	3.40	2.44	12.33	15.08	3.78	A	4.00	A+
	2.0	3.5	3.5	5.0	—	1.40	2.73	2.73	3.64	—	4.40	10.50	11.50	0.55	2.78	3.40	2.44	12.33	15.08	3.78	A	4.00	A+
	2.0	3.5	4.2	4.2	—	1.37	2.68	3.22	3.22	—	4.40	10.50	11.50	0.55	2.78	3.40	2.44	12.33	15.08	3.78	A	4.00	A+
	2.0	3.5	4.2	5.0	—	1.33	2.60	3.12	3.46	—	4.40	10.50	11.50	0.55	2.78	3.40	2.44	12.33	15.08	3.78	A	4.00	A+
	2.0	4.2	4.2	4.2	—	1.31	3.06	3.06	3.06	—	4.40	10.50	11.50	0.55	2.78	3.40	2.44	12.33	15.08	3.78	A	4.00	A+
	2.5	2.5	2.5	2.5	—	2.62	2.62	2.62	2.62	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+
	2.5	2.5	2.5	3.5	—	2.47	2.47	2.47	3.09	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+
	2.5	2.5	2.5	4.2	—	2.33	2.33	2.33	3.50	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+
	2.5	2.5	2.5	5.0	—	2.25	2.25	2.25	3.75	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+
	2.5	2.5	2.5	7.1	—	2.12	2.12	2.12	4.13	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+
2.5	2.5	3.5	3.5	—	2.33	2.33	2.92	2.92	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+	
2.5	2.5	3.5	4.2	—	2.21	2.21	2.76	3.32	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+	
2.5	2.5	3.5	5.0	—	2.14	2.14	2.67	3.56	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+	
2.5	2.5	4.2	4.2	—	2.10	2.10	3.15	3.15	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+	
2.5	2.5	4.2	5.0	—	2.03	2.03	3.05	3.39	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+	
2.5	2.5	5.0	5.0	—	1.97	1.97	3.28	3.28	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+	
2.5	3.5	3.5	3.5	—	2.21	2.76	2.76	2.76	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+	
2.5	3.5	3.5	4.2	—	2.10	2.62	2.62	3.15	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+	
2.5	3.5	3.5	5.0	—	2.03	2.54	2.54	3.39	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+	
2.5	3.5	4.2	4.2	—	2.00	2.50	3.00	3.00	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+	
3.5	3.5	3.5	3.5	—	2.62	2.62	2.62	2.62	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+	
3.5	3.5	3.5	4.2	—	2.50	2.50	2.50	3.00	—	4.40	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+	
5	2.0	2.0	2.0	2.0	2.0	2.10	2.10	2.10	2.10	2.10	4.20	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+
	2.0	2.0	2.0	2.0	2.5	1.89	1.89	1.89	1.89	2.95	4.20	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+
	2.0	2.0	2.0	2.0	3.5	1.76	1.76	1.76	1.76	3.45	4.20	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+
	2.0	2.0	2.0	2.0	4.2	1.65	1.65	1.65	1.65	3.88	4.20	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+
	2.0	2.0	2.0	2.0	5.0	1.59	1.59	1.59	1.59	4.14	4.20	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+
	2.0	2.0	2.0	2.5	2.5	1.71	1.71	1.71	2.68	2.68	4.20	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+
	2.0	2.0	2.0	2.5	3.5	1.61	1.61	1.61	2.52	3.15	4.20	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A	4.00	A+
	2.0	2.0	2.0	2.5	4.2	1.52	1.52	1.52	2.38	3.57	4.20	10.50	11.50	0.55	2.76	3.40	2.44	12.24	15.08	3.80	A		