



LCIE

BV LCIE 1866AS02HAIR27309
CHINA
Number 1866AF02HAIR27309

ATTESTATION of conformity with European Directives

Product: Duct type air conditioner

Reference: 1) 1UH105N1ERG (Outdoor unit) combined with ADH105H1ERG (Indoor unit);
2) 1UH125P1ERG (Outdoor unit) combined with ADH125H1ERG (Indoor unit);
3) 1UH140P1ERG (Outdoor unit) combined with ADH140H1ERG (Indoor unit);
4) 1UH160P1ERG (Outdoor unit) combined with ADH160H1ERG (Indoor unit)

Issued to: Qingdao Haier Air Conditioner Electric Co., Ltd.

Address: Haier Industrial Park, Qianwangang Road, Eco-Tech Development Zone, Qingdao 266555, Shandong, P. R. China.

Manufacturer: Qingdao Haier Air Conditioner Electric Co., Ltd.

Technical characteristics: 220-240V~, 50/60Hz, Class I, IP24 for outdoor unit
For 1) 5300W, 23,2A, R410A/2,5kg;
For 2) 6500W, 30A, R410A/3,7kg;
For 3) and 4) 7200W, 32A, R410A/3,7kg.

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:
- Machinery Directive 2006/42/EC

Standards	Report number	Report date
- EN 60335-1:2012 +A11:2014 +A13:2017 - EN 60335-2-40:2003 +A11:2004 +A12:2005 +A1:2006 +A2:2009 +A13:2012 - EN 62233:2008	HAIR18JA0329DTSP	26/02/2018

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), Feb. 27th, 2018



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.