



LCIE

BV LCIE 1866AS03HAIR27492
CHINA
Number 1866AF03HAIR27492

ATTESTATION of conformity with European Directives

Product: Ducted Type Indoor Unit of Air Conditioner

Reference AD90S2SM3FA, AD105S2SM3FA, AD125S2SM3FA, AD140S2SM3FA,
AD90S2SM4FA, AD105S2SM4FA, AD125S2SM4FA, AD140S2SM4FA

Issued to Qingdao Haier Air Conditioner Electric Co., Ltd.

Address Haier Industrial Park, Qianwangang Road, Eco-Tech Development Zone,
Qingdao 266555, Shandong, P. R. China.

Manufacturer Qingdao Haier Air Conditioner Electric Co., Ltd.

Technical characteristics 220-240V, 50/60Hz, Class I, IPX0, R410A, Max. pressure of refrigerant:
4,15MPa.
200W for AD90S2SM3FA, AD90S2SM4FA, AD105S2SM3FA,
AD105S2SM4FA;
375W for AD125S2SM3FA, AD125S2SM4FA, AD140S2SM3FA,
AD140S2SM4FA.

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

- Machinery Directive 2006/42/EC

Standards	Report number	Report date
- EN 60335-1:2012 +A11:2014 +A13:2017 - EN 60335-2-40:2003 +A11:2004 +A12:2005 +A1:2006 +A2:2009 +A13:2012 - EN 62233:2008	HAIR17OC0979DTSP	22/03/2018

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product

The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), March 22nd, 2018



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
上海欧亚电气技术咨询服务有限公司

Building 4, No. 518, Xin Zhuan Road, CaoHejing
Songjiang High-Tech Park, Shanghai P.R.C
(201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com